

## **NOTES**

- 1. FOR COMBINATION CONCRETE CURB AND GUTTER TYPES A, B, C, AND D SEE STD. NO. MD 620.02 AND STD. MD 620.02-01 EXPANSION JOINTS SEE STD. NO MD 655.01.
- 2. WHEN AN EXISTING ENTRANCE IS LESS THAN 20' IN WIDTH A UNIFORM TAPER SHALL BE CONSTRUCTED TO TIE INTO THE EXISTING ENTRANCE AS DIRECTED BY THE ENGINEER.
- 3. WHEN SIDEWALK IS USED IN SOME CASES. THE BACK EDGE OF THE SIDEWALK MAY HAVE TO BE DEPRESSED SO THAT THE ENTRANCE APRON GRADE WILL NOT EXCEED 12:1 (8.33%) WITHIN THE SIDEWALK AREA.

